




配光特性

図番 YL220018



| | | |
|--------|---------------------------|-----|
| カタログ番号 | K4640(B・W) | |
| 使用ランプ | | |
| 器具光束 | 311.0 lm _{1,000} | |
| 器具効率 | 100.0 % | |
| 下方効率 | 50.0 % | |
| 上方効率 | 50.0 % | |
| 最大取付間隔 | 下方向 | 上方向 |
| A断面 | | |
| C断面 | | |
| B断面 | | |

| | | |
|--|------|----|
|  | 角度 | 光度 |
| | 0° | 54 |
| | 10° | 53 |
| | 20° | 51 |
| | 30° | 46 |
| | 40° | 40 |
| | 50° | 33 |
| | 60° | 25 |
| | 70° | 15 |
| | 80° | 6 |
| | 90° | 0 |
| | 100° | 6 |
| | 110° | 15 |
| | 120° | 25 |
| | 130° | 33 |
| | 140° | 40 |
| | 150° | 46 |
| | 160° | 51 |
| 170° | 53 | |
| 180° | 54 | |



| 照明率表 | | 平均照度=台数×照明率×保守率×311(光束)/(間口×奥行) | | | | | | | | | | | | | |
|------------|------|---------------------------------|------|------|------|------|------|------|------|------|------|------|------|------|------|
| 床面反射率 (%) | | 20 | | | | | | | | | | | | 0 | |
| 天井面反射率 (%) | | 80 | | | 60 | | | 40 | | | 20 | | | 0 | |
| 壁面反射率 (%) | | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 0 | |
| 室 | 0.50 | 0.33 | 0.26 | 0.21 | 0.29 | 0.23 | 0.19 | 0.25 | 0.20 | 0.17 | 0.21 | 0.17 | 0.14 | 0.11 | |
| | 0.70 | 0.44 | 0.36 | 0.31 | 0.38 | 0.32 | 0.27 | 0.33 | 0.28 | 0.24 | 0.27 | 0.24 | 0.21 | 0.16 | |
| | 1.00 | 0.57 | 0.49 | 0.43 | 0.49 | 0.42 | 0.38 | 0.41 | 0.37 | 0.33 | 0.35 | 0.31 | 0.28 | 0.22 | |
| | 1.25 | 0.64 | 0.56 | 0.50 | 0.55 | 0.49 | 0.44 | 0.47 | 0.42 | 0.38 | 0.39 | 0.35 | 0.33 | 0.26 | |
| | 1.50 | 0.69 | 0.62 | 0.56 | 0.60 | 0.54 | 0.49 | 0.50 | 0.46 | 0.43 | 0.42 | 0.39 | 0.36 | 0.29 | |
| | 指 | 2.00 | 0.77 | 0.70 | 0.65 | 0.66 | 0.61 | 0.57 | 0.56 | 0.52 | 0.49 | 0.46 | 0.44 | 0.41 | 0.33 |
| | | 2.50 | 0.82 | 0.76 | 0.71 | 0.70 | 0.66 | 0.62 | 0.59 | 0.56 | 0.53 | 0.49 | 0.47 | 0.45 | 0.36 |
| | | 3.00 | 0.86 | 0.80 | 0.76 | 0.73 | 0.69 | 0.66 | 0.62 | 0.59 | 0.56 | 0.51 | 0.49 | 0.47 | 0.38 |
| | | 4.00 | 0.91 | 0.86 | 0.82 | 0.77 | 0.74 | 0.71 | 0.65 | 0.63 | 0.61 | 0.54 | 0.52 | 0.51 | 0.41 |
| | 数 | 5.00 | 0.94 | 0.90 | 0.86 | 0.80 | 0.77 | 0.74 | 0.67 | 0.65 | 0.63 | 0.55 | 0.54 | 0.53 | 0.42 |
| 7.00 | | 0.97 | 0.94 | 0.92 | 0.83 | 0.81 | 0.79 | 0.70 | 0.68 | 0.67 | 0.57 | 0.56 | 0.55 | 0.44 | |
| 10.00 | | 1.00 | 0.98 | 0.96 | 0.85 | 0.84 | 0.82 | 0.71 | 0.70 | 0.69 | 0.59 | 0.58 | 0.57 | 0.46 | |